


## **Certificate of Compliance**

Certificate:	2518429	Master Contract:	181564		
Project:	80012111	Date Issued:	July 29, 2019		
Issued to:	Delta Electronics (Thailand) Public Co., Ltd. 909 Soi 9 Moo 4 Pattana 1 Rd Bangpoo Industrial Estate E.P.Z. Tambol Phraksa Amphur Muang, Samut Prakan 10280 THAILAND Attention: Mr. Surasit Kansaard				

The products listed below are eligible to bear the CSA Mark shown





## **PRODUCTS**

CLASS 5311 03 - POWER SUPPLIES - Component Type

DIN Rail Buffer Module, component type, Model DRB-24V020ABX and DRB-24V040ABX (where X can be 0-1, a-z, A-Z or blank), permanently connected, intended for use in a controlled environment, rated as follows:

Model	Input		Output		
	Volts (V dc)	Amps (A)	Volts (V dc)	Amps (A)	Power (W)
DRB-24V020ABX	24	20	24	20	480
DRB-24V040ABX	24	40	24	40	960

Notes:

- 1. The wiring terminals are intended for Field wiring.
- 2. Not more than AWG 26~10 with strip length 7~8 mm is used for field wiring terminals.
- 3. The above buffer module has been evaluated in an ambient of 70°C@100% power and 75°C@75% power.
- 4. The above buffer module is certified only as a component for use in other equipment, where the suitability of the combination is to be determined in the end product.



 Certificate:
 2518429

 Project:
 80012111

Master Contract: 181564 Date Issued: July 29, 2019

## **APPLICABLE REQUIREMENTS**

CSA-C22.2 No. 107.1-16 - Power Conversion Equipment