



Ref. Certif. No.

SI-6077

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

DIN Rail Power Supply

Name and address of the applicant

Delta Electronics (Thailand) Public Co., Ltd.
909 Soi 9, Moo 4, Bangpoo Industrial Estate (E.P.Z.),
Pattana 1 Road, Tambol Phraksa, Amphur Muang,
Samutprakarn TH-10280, Thailand

Name and address of the manufacturer

Delta Electronics (Thailand) Public Co., Ltd.
909 Soi 9, Moo 4, Bangpoo Industrial Estate (E.P.Z.),
Pattana 1 Road, Tambol Phraksa, Amphur Muang,
Samutprakarn TH-10280, Thailand

Name and address of the factory

See page 2

Note: When more than one factory, please report on page 2 Additional Information on page 2

Ratings and principal characteristics

See page 2

Trademark (if any)

DELTA ELECTRONICS, INC.

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

1) DRP-24V480W1CAX(y)
2) DRP-24V480W1CBX(y)
where X: any alphanumeric or blank, (y): any
alphanumeric or blankAdditional information (if necessary may also
be reported on page 2)

/

 Additional Information on page 2A sample of the product was tested and found
to be in conformity withIEC 60950-1:2005 (2nd Edition) + A1:2009 + A2:2013As shown in the Test Report Ref. No. which
forms part of this Certificate

T223-0306/17

This CB Test Certificate is issued by the National Certification Body

SIQ Ljubljana, Tržaška cesta 2, SI-1000 Ljubljana, Slovenia
T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.siSIQ Ljubljana is accredited by Slovenian Accreditation with accreditation number CP-001 in the
field of certification of products, processes and services.

Date: 2017-07-06

Signature: Bojan Pečavar

Name and address of the factories:

- 1) Delta Electronics (Thailand) Public Co., Ltd.
909 Soi 9, Moo 4, Bangpoo Industrial Estate (E.P.Z.), Pattana 1 Road, Tambol Phraksa, Amphur Muang, Samutprakarn TH-10280, Thailand
- 2) Delta Electronics (Jiangsu) LTD.
No 1688 Jiangxing East Rd., Wujiang Economic Development Zone, Wujiang City, Jiangsu Province, CN-215200, China

Ratings and principal characteristics:

Input:

DRP-24V480W1CAX(y): 100-240 Vac; 5.5 A; 50-60 Hz

DRP-24V480W1CBX(y): 100-240 Vac; 5.5 A; 50-60 Hz & 110-300 Vdc; 5.5 A

Output:

24 Vdc; 20 A (18 A for horizontal orientation)

Output is adjustable from 24 to 28V with max output power 480 W (432W for horizontal orientation)

Additional information (if necessary)

Date: 2017-07-06

Signature: Bojan Pečavar

