

Ref. Certif. No.

DK-137309-M1-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME **CB TEST CERTIFICATE** Independent LED Controlgear Product DELTA ELECTRONICS INC Name and address of the applicant 3 Tungyuan Road Chungli Industrial Zone Taoyuan City 32063 Taiwan DELTA ELECTRONICS INC Name and address of the manufacturer 3 Tungyuan Road Chungli Industrial Zone Taoyuan City 32063 Taiwan Delta Electronics (Wuhu) Ltd Name and address of the factory No. 138 Jiuhua North Road Longshan Street Economic Technical Development Area Wuhu City, Anhui Province, 241009 Note: When more than one factory, please report on page 2 China Additional Information on page 2 Input: 220-400 V~ 50/60 Hz 10-5.4 A λ>0.95 2190W(Max) Ratings and principal characteristics Additional Information on page 2 Trademark / Brand (if any) Customer's Testing Facility (CTF) Stage used EUCO-2K1200GDAXX, EUCO-2K1200GIAXX Model / Type Ref. Additional Information on page 2 Additionally evaluated to: EN 61347-2-13:2014, EN 61347-2-Additional information (if necessary may also be 13:2014/A1:2017, EN 61347-1:2015, EN 61347-1:2015/A1:2021 reported on page 2) The report was revised to include technical modifications. National Differences: EU Group Differences, AU, NZ Additional Information on page 2 A sample of the product was tested and found IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 61347-1:2015, to be in conformity with IEC 61347-1:2015/AMD1:2017 As shown in the Test Report Ref. No. which forms 4790650795.1 Amendment 1 issued on 2023-07-26 part of this Certificate This CB Test Certificate is issued by the National Certification Body UL Solutions (US), 333 Pfingsten Rd IL 60062, Northbrook, USA □ UL Solutions (Demko), Borupvang SA DK-2750 Ballerup, DENMARK □ UL Solutions (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN □ UL Solutions (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA Solutions For full legal entity names see www.ul.com/ncbnames - fhlip Date: 2023-07-27 Signature: Original Issue Date: 2023-02-03 **Thomas Wilson**



Ref. Certif. No.

DK-137309-M1-UL

Additional Model Detail(s): EUCO-2K1200GDAXX, EUCO-2K1200GIAXX, X=0-9, A-Z or blank **Additional Ratings:** Output (3 independent channels): 250-550 V --- Uout = 600 V --- max (No load), 700-2000 mA Constant current output 2100 W max. Vaux: +24V === 125 mA (EUCO-2K1200GIAXX only) ta= -40...+50°C, tc= +85°C 17 👧 Class I, Summary of Modifications: - Add additional EMI board/components and minor change construction; Update enclosures; See test report for details Additional information (if necessary) □ UL Solutions (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
☑ UL Solutions (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
□ UL Solutions (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
□ UL Solutions (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA Solutions For full legal entity names see www.ul.com/ncbnames Date: 2023-07-27 Signature: The I Wil Original Issue Date: 2023-02-03 Thomas Wilson