

Certificate of Compliance

Certificate:	1761784	Master Contract:	181564
Project:	80005441	Date Issued:	June 5, 2019
Issued to:	Delta Electronics (Thailand) Public Co. 909 Soi 9 Moo 4 Pattana 1 Rd Bangpoo Industrial Estate E.P.Z. Tambol Phraksa, Amphur Muang, Samut Prakan 10280 THAILAND Attention: Sittiruk Subniem	, Ltd.	

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by:

Edwin Chao

PRODUCTS

CLASS – 3211 87 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus - Certified to US Standards. (UL 508) CLASS – 5311 03 - POWER SUPPLIES - Component Type - (CSA 107.1-16). CLASS – 5311 07 - POWER SUPPLIES - Component Type - (CSA 60950-1-03) CLASS – 5311 87 - POWER SUPPLIES - Component Type - Certified to US Stds. - (CSA 60950-1-03/UL 60950-1, First Edition, NRTL Program)

• Component type switch mode power supply unit*, DIN rail mounting type, Model: D0116888 or DRP024V060W1AZX (where X can be 0-1, a-z, A-Z or blank), Nominal Input rating: 100-240Vac, 50-60Hz, 1.5A, Output rating: 24Vdc, 2.5A and (Input Rating: 120-375Vdc, Output rating: 24-28Vdc, 2.5A)*.

Notes (*):

- § The unit was evaluated as component, were the suitability of the combination with the final product or host equipment will need to be re-evaluated.
- § Units were evaluated for a maximum rated ambient of 50°C, with derated output at increased ambient temp.
- § An appropriate fire enclosure shall be provided with the end use application.
- § Unit's other operating ranges: 120-375Vdc, Output rating: 24-28Vdc, 2.5A).

BI-NAT Std. CSA 60950-1-03/UL 60950-1, 1st Edition DESIGN MANUAL Ver. 1.0 IS AN INTEGRAL PART OF THIS REPORT



Certificate: 1761784 **Project:** 80005441 Master Contract: 181564 **Date Issued:** June 5, 2019

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 60950-1-03 - Information Technology Equipment – Safety – Part 1: General requirements. UL 60950-1 (1st Edition)

- Information Technology Equipment – Safety – Part 1: General requirements

- CSA-C22.2 No. 107.1-16 UL Std 508 (17th Edition)
- Power conversion equipment
- Industrial Control Equipment