



# Licence

### for the use of SIQ Type Approved certification mark

Number:	SI-SIQ BG 004/257	Project file:	C20200676	
Product:	DIN Rail Power Supply			
Type reference:	EOE11010006 or DRP024V060W1AX; X = A-Z, 0-9 or blank			
Trademark:	DELTA ELECTRONICS, INC.			
Ratings:	Input:100-240 Vac; 50-60 Hz; 1,5 A or 120-250 Vdc; 1,5 A; Output: 24 Vdc; 2,5 A			
Applicant / Licensee: Delta Electronics (Thailand) Public Co., Ltd. 909 Soi 9, Moo 4, Bangpoo Industrial Estate (E.P.Z.), Pattana 1 Road, Tambol Phraksa, Amphur Muang, Samutprakarn TH-10280, Thailand				
Manufacturer:	Delta Electronics (Thailand) Public Co., Ltd. 909 Soi 9, Moo 4, Bangpoo Industrial Estate (E.P.Z.), Pattana 1 Road, Tambol Phraksa, Amphur Muang, Samutprakarn TH-10280, Thailand			

SIQ hereby grants the right to use the SIQ Type Approved certification mark of conformity on the products specified in this document. The SIQ Type Approved certification mark of conformity signifies the compliance of the products with requirements of cited standards.

Certification mark:



Standard: EN 62368-1:2014 + A11:2017

Test report: T223-0242/20 (2020-04-28)

Remarks:

This licence has been issued under the presumption and conditional on the fact that the licensee holds all necessary legal rights with regard to the product presented for testing and certification.

This licence is valid as long as the conditions laid down in the listed standards are not modified significantly and until the licensee complies with the SIQ's rules on product certification.

Date: 2020-04-28

Authorized signature: Bojan Pečavar

R\_B\_

Only integral publication of this licence is allowed. This licence may only be reproduced in its entirety and without any changes. On request SIQ will give information about the validity of the licence.

## Licence for the use of SIQ Type Approved certification mark

Number:

SI-SIQ BG 004/257

### Additional remarks:

The list of critical components of the product for which this licence is granted is included in the test report.

Unit was also investigated and found to be in compliance with clearance and creepage distance requirements of clause 4.4.7.4 and 4.4.7.5 of IEC/EN 62477-1:2012 +A11:2014 for OVC III and altitude of 2000m. Output was classified as DVC A. DVC A means that output meets SELV limits for an area of contact equal to human hand under dry condition.

Requirements in EN 60204-1:2006 + A1:2009 (clearance and creepage distances) and IEC 62103-1:2003 (safety part only) are also verified and found to be less strict than in above mentioned standards. Output must be earthed in the final unit in order to comply with PELV requirements according to standard EN 60204-1:2006 + A1:2009.

### Places of manufacture, inspection file number:

Delta Electronics (Thailand) Public Co., Ltd. 909 Soi 9, Moo 4, Bangpoo Industrial Estate (E.P.Z.), Pattana 1 Road, Tambol Phraksa, Amphur Muang, Samutprakarn TH-10280, Thailand (Inspection file number: 16343-16343)

Delta Electronics (Jiangsu) Ltd. No. 1688 Jiangxing East Road, Wujiang Economics Development Zone, Song Ling Town, Wujiang City, Jiangsu Province, CN-215200, P.R China (Inspection file number: 16343-27133)

Limitation:

Date: 2020-04-28

1

Authorized signature: Bojan Pečavar

R-Bj-

SIQ Ljubljana, Mašera-Spasićeva ulica 10, SI-1000 Ljubljana, Slovenia T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si





# Licence

### for the use of SIQ Type Approved certification mark

Number:	SI-SIQ BG 004/256	Project file:	C20200676	
Product:	DIN Rail Power Supply for Building-in			
Type reference:	EOE11010006 or DRP024V060W1AX; X = A-Z, 0-9 or blank			
Trademark:	DELTA ELECTRONICS, INC.			
Ratings:	Input:100-240 Vac; 50-60 Hz; 1,5 A or 120-250 Vdc, 1,5 A; Output: 24 Vdc; 2,5 A			
Applicant / Licensee: Delta Electronics (Thailand) Public Co., Ltd. 909 Soi 9, Moo 4, Bangpoo Industrial Estate (E.P.Z.), Pattana 1 Road, Tambol Phraksa, Amphur Muang, Samutprakarn TH-10280, Thailand Delta Electronics (Thailand) Public Co., Ltd. 909 Soi 9, Moo 4, Bangpoo Industrial Estate (E.P.Z.), Pattana 1 Road,				
	Tambol Phraksa, Amphur Muang, Samutpral			

SIQ hereby grants the right to use the SIQ Type Approved certification mark of conformity on the products specified in this document. The SIQ Type Approved certification mark of conformity signifies the compliance of the products with requirements of cited standards.

Certification mark:



Standard:

Test report: T223-0241/20 (2020-04-23)

Remarks:

This licence has been issued under the presumption and conditional on the fact that the licensee holds all necessary legal rights with regard to the product presented for testing and certification.

EN 60950-1:2006 + A1:2010 + A2:2013 + A11:2009 + A12:2011

This licence is valid as long as the conditions laid down in the listed standards are not modified significantly and until the licensee complies with the SIQ's rules on product certification.

Date: 2020-04-23

Authorized signature: Bojan Pečavar

-Bj-

Only integral publication of this licence is allowed. This licence may only be reproduced in its entirely and without any changes. On request SIQ will give information about the validity of the licence.

SIQ Ljubljana, Mašera-Spasićeva ulica 10, SI-1000 Ljubljana, Slovenia T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si

## Licence for the use of SIQ Type Approved certification mark

Number:

SI-SIQ BG 004/256

### Additional remarks:

The list of critical components of the product for which this licence is granted is included in the test report.

Unit was also investigated and found to be in compliance with clearance and creepage distance requirements of clause 4.4.7.4 and 4.4.7.5 of IEC/EN 62477-1:2012 +A11:2014 for OVC III and altitude of 2000m. Output was classified as DVC A. DVC A means that output meets SELV limits for an area of contact equal to human hand under dry condition.

Requirements in EN 60204-1:2006 + A1:2009 (clearance and creepage distances) and IEC 62103-1:2003 (safety part only) are also verified and found to be less strict than in above mentioned standards. Output must be earthed in the final unit in order to comply with PELV requirements according to standard EN 60204-1:2006 + A1:2009.

### Places of manufacture, inspection file number:

Delta Electronics (Thailand) Public Co., Ltd. 909 Soi 9, Moo 4, Bangpoo Industrial Estate (E.P.Z.), Pattana 1 Road, Tambol Phraksa, Amphur Muang, Samutprakarn TH-10280, THAILAND (Inspection file number: 16343-16343)

Delta Electronics (Jiangsu) Ltd. No. 1688 Jiangxing East Road, Wujiang Economics Development Zone, Song Ling Town, Wujiang City, Jiangsu Province, CN-215200, P.R China (Inspection file number: 16343-27133)

### Limitation:

This SI-SIQ BG licence substitutes previously issued SI-SIQ BG 004/112 licence, dated 2016-03-08, due to update of the report.

Date: 2020-04-23

### Authorized signature: Bojan Pečavar

R\_Bj

SIQ Ljubljana, Mašera-Spasićeva ulica 10, SI-1000 Ljubljana, Slovenia T +386 1 4778 100, F +386 1 4778 444, info@sig.si, www.sig.si